

SPL-201911-0038 dated 19.11.2019

Saraswaty Press Ltd invites sealed tender from experienced vendors for supply, installation, testing & commissioning of Fire Fighting System including necessary civil work at Saraswaty Press Ltd-Unit III (Madyamgram). Offers should reach to Purchase Committee, Saraswaty Press Ltd., 11, B. T. Road, Kolkata-700056 by 26.11.2019 up to 2 p.m. as per attached sheet (Annexure-1). with all statutory compliances documents like PAN, GST, P.F., ESI, Trade License and credentials. The Purchase Committee reserves the right to negotiate/ accept/reject any or all Bids, at its own discretion.

## ANNEXURE-1

## BOQ FOR SUPPLY, INSTALLATION, TESTING &amp; COMMISSIONING OF FIRE FIGHTING SYSTEM INSIDE THE NEW SHEDS AT SPL III AT MADYAMGRAM

Sr. No.	Description	Make	Unit	Qty	SUPPLY		INSTALLATION	
					Unit Rate	Total Amount	Unit Rate	Total Amount
<b>A</b>	<b>FIRE SPRINKLER SYSTEM</b>							
1.0	Providing & fixing MS black steel pipe Medium grade conforming to IS : 1239 including all forged fittings socket weld ( 25 nb to 50 nb ) viz. Elbows, tees, flanges, etc. reduces clamps, MS support dash fasteners etc. including painting the pipe with one coat of approved red oxide primer and two coats of approved red enamel paint and welded joints complete with cutting and making good the walls, floors or any other surface (For sprinkler system)	JINDAL/TATA						
a	150 nb		mtr	84.0				
b	100 nb		mtr	96.0				
c	80 nb		mtr	36.0				
d	65 nb		mtr	12.0				
e	50 nb		mtr	90.0				
f	40 nb		mtr	366.0				
g	32 nb		mtr	138.0				
h	25 nb		mtr	246.0				
2.0	Providing & fixing Wafer Type Butterfly Valve, PN-16 of AL Alloy body , PN-16 with EPDM Seat, Disc of SS-316, Stem of 13 CrSS complete including matching flanges, nuts & bolts	KITZ/AUDCO/NEWAGE						
a	Size 100 mm		nos	4.0				
b	Size 50 mm		nos	3.0				
3.0	68 degree centegrade Pendent Sprinkler	HD	nos	310.0				
4.0	25 mm ball valve	ZOLOTO/LEADER	nos	4.0				
5.0	Structural Support, MS plate etc	ISI	kg	500.0				
6.0	80 nb mild steel medium pipe for vertical support	JINDAL/TATA	mtr	78.0				
<b>B</b>	<b>FIRE DETECTION SYSTEM</b>							
1.0	Smoke Detector	Morley - Honeywel	Nos	75.0				
2.0	2 Loop Networkable type addressable Fire Alarm cum detection panel with loop cards	Morley - Honeywel	Nos	1.0				
3.0	2C x 1.5 sqmm armoured FRLS Control Cable with fittings - RED COLOUR	Polycab	Mtr	3000.0				
4.0	Manual Call Point	Morley - Honeywel	Nos	6.0				
5.0	24 volt Conventional Hooter	System Sensor/Agni	Nos	6.0				
6.0	Control Relay Module	Morley - Honeywel	Nos	6.0				
7.0	24 Volt SMPS	Indegenious	Nos	1.0				
8.0	600 VA UPS	APC	Nos	1.0				
<b>GRAND TOTAL</b>						-		-
Total Supply & Installation in INR								-
<a href="#">GST@ 18 %</a>								-
Total amount after TAX								-
							R/OFF	